

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192709
Address: 4516 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------------|----------|---------------------------|
| Occupancy Inspection - Codes Residential | Patrick Schonfeldt | Failed | Wednesday, April 22, 2020 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Guardrail required at front porch, more than 30" above grade- Complete final grade and sod- Seal all exterior penetrations- Seal around all exterior light fixtures- Obtain lawn irrigation system permit and submit backflow certification- Place splashblocks at all downspout and sump pump discharge locations for minimum distance from foundation 36" |
|---|------|--|

Comments: