

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193356
Address: 4401 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Wednesday, April 22, 2020

Corrective Action Required:

1	Misc	- PROVIDE 800LB HOLDDOWNS PER PLAN EC#2 - - PROVIDE PFH PORTAL FRAMING GARAGE DOOR PER PLAN - - PROVIDE MISSING TRUSS HANGERS PER TRUSS LAYOUT SCHEDULE - - SEAL UPWARD PENETRATIONS AT TOP PLATE @ CLOSET BED #2 &NPLUMBING & ELECTRICAL GARAGE - PROVIDE BOCA PLATES PLUMBING MASTER TUB - - SEAL FIRE BLOCK AT CHASE GREAT ROOM - - NAIL SHEATHING AT STAIRWAY -
---	------	--

Comments: