

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200534
Address: 3201 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Michael Harkins	Failed	Thursday, April 23, 2020

Corrective Action Required:

1	DCM2 Erosion Control	- PROVIDE GRAVEL FILTER - - MAINTAIN SILT FENCE -
---	----------------------	------------------------------------------------------

Comments: