

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193026  
Address: 141 NW MACKENZIE DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Michael Harkins	Failed	Thursday, April 23, 2020

Corrective Action Required:

1	DCM2 Erosion Control	- MAINTAIN SILT FENCE UNTIL SOD COMPLETE -
---	----------------------	--

**Comments:**