

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192808  
Address: 152 NW CARSON DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Michael Harkins	Passed	Thursday, April 23, 2020

Informational:  
1 Misc 3RD PARTY BY TODD LAGENHORST @ VDA SIGNED & STAMPED BY CHAD STREETER. -  
COMMENTS APPROVED HOUSE & DECK PIERS  
(48) SIZE 24" DEPTH 9-13' BEARING LIMESTONE -

**Comments:**