

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192808
Address: 152 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Thursday, April 23, 2020

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | - TIGHTEN ACHOR BOLTS BASEMENT -
- FIRE BLOCK SEAL OPR INSULATE DUCT ABOVE DOOR TO SUSPENDED GARAGE -
- PROVIDE DETAILS FOR SUSPENDED GARAGE -
- ADDRESS BEAM ABOVE BASEMENT BATH OVERSIZED TO DELETE SCH 40
COLUMN -

- NOTE: HAMMER ARRESTORS IN WALL BASEMENT LAUNDRY - |
|---|------|--|

Comments: