

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191955  
Address: 920 NE DEERBROOK ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Khanh Nguyen	Partial	Thursday, April 23, 2020

Corrective Action Required:

1 Misc

**\*\*FOOTING INSPECTED BY 3RD PARTY (NOT INSPECTED BY CITY) SHALL BE APPROVED BY ENGINEER OF RECORD AND DOCUMENT SUBMITTED TO THE CITY**

FROST FOOTING INSPECTED BY CITY-OK TO POUR: FROM E/20 CW TO L/2; U/1 TO X/1. UFER REBAR INSTALLED NEAR SERVICE LOCATION AT X/1

SW AND NE STAIR ENCLOSURE FOOTINGS OK

INTERIOR FOOTING: FOOTING LINE 2 TO 19-OK

**Comments:**