

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193316  
Address: 1626 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Friday, April 24, 2020

Corrective Action Required:

1	Misc	- provide anchor bolts within 12" of plate break family room basement - - tighten anchor bolts & provide nuts & washers basement - - address rafters landing on blocks - - valley strut in garage more than 45 degrees -
---	------	---

**Comments:**