

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20192844
Address: 2931 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Construction Inspection	John Jackson	Partial	Wednesday, November 27, 2019

Informational:
1 6" C-900 water Line A was completely installed, next week testing of Line will begin. Thurst blocks were poured behind bends & tees and bolts for Mega lugs & restraints were sprayed with black epoxy. 11/27/19

Comments: