

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190683
Address: 3301 NE RALPH POWELL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Friday, April 24, 2020

Corrective Action Required:

1	Misc	-Check to make sure CPVC in plenum to meet flame spread and smoke develop indexes. Check all cables to be plenum-rated -Return air not provided from room 142 -Install ceiling return air in rm 148 -Complete bathroom (134) fan exhaust to outside
---	------	--

Comments: