

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20190654

Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 640812020 NW OBRIEN RD, LEES SUMMIT, MO 64081500
NW PRYOR RD, LEES SUMMIT, MO 64081450 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Coliform Test 1	Ronald Paynter	Partial	Friday, April 24, 2020

Informational:

1 Misc

Water lines 4, 5, 6, 7, 8 and 9 have been chlorinated. We will start dechlorinating tomorrow at 1:30 PM. RP 4-23-20

Informational:

2 Misc

We dechlorinated the water lines today. We will pull the first Bac T samples on Monday morning. RP 4-24-20

Comments: