

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172531
Address: 257 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Monday, April 27, 2020

Corrective Action Required:
1 THIRD FLOOR SOUTH END -
 - 308 BOCA PLATE MECHANICAL ROOM DECK -
 - 306 FIRE COLLAR TUB DEAD SPACE -
 - 305 FIRE CAULK DEAD SPACE KITCHEN ISLAND BOTTOM PLATE -

Corrective Action Required:
2 SECOND FLOOR SOUTH END
 -G12 TUB TRAB ABOVE DOORWAY-

Corrective Action Required:
3 FIRST FLOOR SOUTH END -
 - 106 FIRE COLLARS TUB DEAD SPACE -
 - 108 FIRE COLLARS TUB DEAD SPACE -
 - TERRACE ENTRY JOIST HANGERS -

Comments: