

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20200272  
Address: 4408 SW NAUTILUS PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Patrick Schonfeldt	Failed	Monday, April 27, 2020

Corrective Action Required:

1	Misc	- PROVIDE (4) # 4 VERTICAL BARS PER PLAN - (2) 24 X 36 - STANDING WATER IN PIER -
---	------	---

**Comments:**