

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20190654

Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 640812020 NW OBRIEN RD, LEES SUMMIT, MO 64081500  
NW PRYOR RD, LEES SUMMIT, MO 64081450 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Coliform Test 1</b>	Ronald Paynter	Partial	Monday, April 27, 2020

Informational:

1 Misc

Water lines 4, 5, 6, 7, 8 and 9 have been chlorinated. We will start dechlorinating tomorrow at 1:30 PM. RP 4-23-20

Informational:

2 Misc

We dechlorinated the water lines today. We will pull the first Bac T samples on Monday morning. RP 4-24-20

Informational:

3 Misc

Pull 5 water samples for Bac T testing with Daniel. Dropped the samples off at Keystone Laboratories for testing. Will get the results back tomorrow. RP 4-27-20

**Comments:**