

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191580
Address: 1503 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Michael Harkins	Passed	Tuesday, April 21, 2020

Informational:	
1 Misc	3RD PARTY DRILLED PIERS BY DEREK PEREZ @ RES SIGNED & STAMPED BY BRADLEY HUXOL COMMENTS DRILLED PIERS APPROVED FOR CONCRETE. SIZE 18" DEPTH 5-8' BEARING LIMESTONE

Comments: