

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193399
Address: 1516 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, April 28, 2020

Corrective Action Required:

1	Misc	- FLASHING ABOVE GARAGE DOOR - - PFH PORTAL FRAME PER PLAN GARAGE DOOR - - NAIL JOIST HANGERS ABOVE BASEMENT STAIRS - - EXHAUST FAN BASEMENT BATH - - REPLACE MISSING STUDS LAUNDRY - - PROVIDE (4) 2X4 UNDER LVLs LAUNDRY - - PROVIDE ACCESS TO JACUZZI GFCI/MOTOR - - NAIL GUARD PLUMBING MASTER SHOWER - - JOIST HANGER TRIPLE LVLs MASTER AT BEAM - - PROVIDE 800 LB HOLD DOWNS EC#2 PER PLAN - - FRAMING AIR RETURN 2ND FLOOR HALL - - SNOW BLOCKING BED # 4 BATH & CLOSET - - MISSING H 2.5 BED # 3 - - ATTIC ACCES 2ND STORY PER PLAN -
---	------	---

Comments: