

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182387
Address: 2023 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Michael Harkins	Not Ready	Friday, March 20, 2020

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	rooms approved for top rock of roof truss. ; 101-05,115-118;
---	----------------------------------	--

Comments: