

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20172531  
Address: 257 NW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Michael Harkins	Failed	Tuesday, April 28, 2020

Corrective Action Required:

1	THIRD FLOOR	SOUTH END - - 308 BOCA PLATE MECHANICAL ROOM DECK - - 306 FIRE COLLAR TUB DEAD SPACE - - 305 FIRE CAULK DEAD SPACE KITCHEN ISLAND BOTTOM PLATE - NORTH END -G1 STRAP & FIRE CAULK TOP PLATE - - 304 MECH ROOM HOLE IN FLOOR, FIRE CAULK DEAD SPACE - - 301 PLUMBING NAIL GUARD LAUNDRY -
---	-------------	---

Corrective Action Required:

2	SECOND FLOOR	SOUTH END -G12 TUB TRAB ABOVE DOORWAY-
---	--------------	---

Corrective Action Required:

3	FIRST FLOOR	SOUTH END - - 106 FIRE COLLARS TUB DEAD SPACE - - 108 FIRE COLLARS TUB DEAD SPACE - - TERRACE ENTRY JOIST HANGERS -
---	-------------	--

**Comments:**