

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20191131  
Address: 1420 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Erosion Sediment Control (ESC) Inspection</b>	Joe Starlin	Partial	Wednesday, April 29, 2020

Informational:  
1 Misc 2-21-20 8:30am I spoke with the Superintendent. There is silt fence down on the east side of the job site that needs addressed. All other erosion controls appear at this time to be good. The Superintendent said he would make the corrections right away.

Informational:  
2 Misc 3-27-20 10am Most of the erosion appears to be in place and working. The superintendent said that they are coming out today to check and do any repairs. 4-29-20 8:38am All of the erosion controls are in place and appear to be working at this time.

**Comments:**