

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20182652
Address: 2100 SW LADDERBACK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Erosion Sediment Control (ESC) Inspection	John DiMauro	Failed	Wednesday, April 29, 2020

Corrective Action Required:

3	Misc	FAILED EROSION CONTROL INSPECTION
---	------	-----------------------------------

THE SILT FENCE ALONG SW LADDERBACK DR AND JUST EAST OF SW HICKORY LN HAS FAILED AND IS ALLOWING SILT AND MUD TO COLLECT INTO THE STORM WATER COLLECTION SYSTEM. MAKE CORRECTIONS TO THE SILT FENCE AND CLEAN THE MUD FROM THE INLET ASAP.

Comments: