

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172515
Address: 225 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Wednesday, April 29, 2020

Corrective Action Required:

1	Misc	- INSTALL GARAGE DOOR OPENERS, DOORS BUTTONS, SENSORS & FIRE CAULK - -NORTH BASEMENT HALL EXIT SIGN NOT INSTALLED - - NORTH EXIT POUR LANDING, OPEN BOX CEILING, SOFFIT NOT INSTALLED - - SOUTH BASEMENT FIRE ALARM PANEL ROOM HOLE IN CEILING CUT FROM RC CHANNEL TO RC AND SCREW, FIRE CAULK CEILING PENETRATIONS, FIRE CAULK SPRINKLER PIPE ABOVE DOOR - - FIRE CAULK STAND PIPES - - 207 HOLE IN CEILING LAUNDRY CUT RC TO RC & SCREW, DECK RAILING SHALL NOT ALLOW 4" SPHERE TO PASS THROUGH - - 205 GFCI RIGHT OF KITCHEN SINK DEAD - - G7-2 FLUSH MOUNT CLEAN OUT - - PROVIDE TAMPER PROOF CAPS A/C CONDENSORS - -
---	------	--

Comments: