

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193399
Address: 1516 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, April 30, 2020

Corrective Action Required:

1	Misc	- FLASHING ABOVE GARAGE DOOR - - NAIL JOIST HANGERS ABOVE BASEMENT STAIRS - - ATTIC ACCES 2ND STORY PER PLAN -
---	------	--

Informational:

2	Misc	- Dustin stated Jacuzzi tub motor access will be added during trim -
---	------	--

Comments: