



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20190683	Date:	April 30, 2020
Project Title:	GODDARD SCHOOL	Applicant:	
Location:			
3301 NE RALPH POWELL RD, LEES SUMMIT, MO 64064		TECH ELECTRONICS OF KANSAS	
Type of Work:		8202 MARSHAL DR	
Occupancy Group:	E	LENEXA, KS 66214	
Description:	NEW DAYCARE FACILITY		
Construction Type:	Type VB (Unprotected)	Primary:	(785) 379-0300
Map Page:	175M		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

2. (ACTION REQUIRED)

1. Provide a smoke detector over the FACP
2. Add strobe in Room 149
3. Add Horn/Strobes in Rooms 103 and 107

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.