

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193015
Address: 3001 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, April 30, 2020

Corrective Action Required:

1	Misc	- Submit as graded plot plan for review - - Hammer arrestors at laundry and kitchen - - Sliding patio door locks and handle - - Submit pier inspection report -
---	------	--

Comments: