

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193014
Address: 3005 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, April 30, 2020

Corrective Action Required:

1	Misc	- Obtain lawn irrigation system permit and submit backflow certification - Splash blocks at all downspouts - - Secure AC electrical whip within 12" of disconnect - - Complete range hood installation - - handle and locks at sliding patio door - - Remove paint cover on smoke in basement -
---	------	---

Comments: