

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193356
Address: 4401 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, April 30, 2020

Corrective Action Required:

1	Misc	- PROVIDE 800LB HOLDDOWNS PER PLAN EC#2 - 2ND FLOOR MASTER BED, BED #2 - SEAL UPWARD PENETRATIONS AT TOP PLATE @ CLOSET BED #2 & NPLUMBING & ELECTRICAL GARAGE
---	------	---

Comments: