

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20193157
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Construction Inspection	Joe Starlin	Partial	Friday, May 01, 2020

Informational:
1 Misc 4-21-20 2:44pm ESS as installed 2 sticks of 6" waterline and 2 sticks of 4" waterline coming out of the vault. They are now backfilling. 5-1-20 The water line is ran to the building from the vault.

Comments: