

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200840
Address: 2914 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Deck Final Inspection - Residential	Michael Harkins	Passed	Friday, May 01, 2020

Corrective Action Required:

1	Misc	poured with footing (1) 18 X 36 W/ (4) # 4 VERT
---	------	---

Comments: