

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193064
Address: 2942 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, May 01, 2020

Corrective Action Required:

1	Misc	- PROVIDE 4 SOFFIT VENT @ COVERED DECK PER PLAN - - STRAP TOP PLATE ABOVE FIREPLACE - - PROVIDE ANCHOR BOLT @ PLATE BREAK BED #3 CLOSET - - NO COVERED DECK PIER INSPECTIONS ON RECORD -
---	------	---

Comments: