

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193576  
Address: 2927 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Residential</b>	Patrick Schonfeldt	Failed	Tuesday, May 05, 2020

Corrective Action Required:

1	Misc	- Remove green bonding screw at electric sub panel and set bonding screw on main panel - Color code ufer ground at panel
---	------	---

**Comments:**