

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200267
Address: 133 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Partial	Wednesday, May 06, 2020

Informational:	
1 Misc	PFH GARAGE PORTAL FRAMING HOLD DOWNS, NAILING PATTERN, HEADER TO JACK STUD STRAPS, 5/8 ANCHOR BOLTS OK TO COVER -

Comments: