

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20191897  
Address: 3221 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Curb New/Replacement</b>	Ronald Paynter	Partial	Wednesday, May 06, 2020

Informational:	
1 Misc	Curb inspection found 12 curb sections that are broken / cracked. Personnel from Public Works will do final inspection before acceptance. RP 3-27-20
Informational:	
2 Misc	Freedom Concrete removed the cracked curbs that needed replacing. They have drilled and placed dowel bars into the curbs, along with expansion joints. RP 5-6-20

**Comments:**