

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20170397  
Address: 3510 SW HOLLYWOOD DR, Unit:1, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Michael Harkins	Partial	Wednesday, May 06, 2020

Informational:  
4 STAIR TOWER 2 1st layer type c OK  
2ND LAYER TYPE C OK  
3RD LAYER TYPE C & RC CHANNEL OK  
4TH LAYER OK TO TAPE

Informational:  
5 STAIR TOWER 3 1st layer type C OK  
2ND LAYER TYPE C OK  
3RD LAYER TYPE C & RC CHANNEL OK  
4TH LAYER OK TO TAPE

Informational:  
6 STAIR TOWER 4 1st layer type C OK  
2ND LAYER TYPE C OK  
3RD LAYER TYPE C & RC CHANNEL OK  
4TH LAYER TYPE C OK TO TAPE

Corrective Action Required:  
7 FIRST FLOOR 1ST FLOOR CEILING WALLS UNITS & CORRIDOR OK TO TAPE

Informational:  
1 Misc 2nd LAYER TYPE C 3RD FLOOR UNITS & STAIRWAYS

Informational:  
2 Misc screw pattern 2nd floor units walls & ceilings OK

Informational:

3	STAIR TOWER 1	1st layer type c OK 2ND LAYER TYPE C OK 3RD LAYER TYPE C & RC CHANNEL OK 4TH LAYER OK TO TAPE
Corrective Action Required:		
8	LOWER LEVEL	WALLS & CEILING OK TO TAPE

**Comments:**