

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172525
Address: 249 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Wednesday, May 06, 2020

Corrective Action Required:

1	THIRD FLOOR	SOUTH EAST END - 308 ROOF BOOTS ABOVE TUB, H 2.5s EXTERIOR WALL - - 307 H 2.5s EXTERIOR WALL - - 306 ROOF BOOTS - NORTH END 304 FIRE COLLAR DEAD SPACE ROOF BOOTS THROUGHOUT
---	-------------	--

Corrective Action Required:

2	SECOND FLOOR	- 206 FIRE COLLAR DEAD SPACE - NORTH END - 204 WATER LINE MECH CLOSET NOT CAPPED OR HOOKED UP -
---	--------------	---

Corrective Action Required:

3	FIRST FLOOR	- 106 FIRE BLOCK DEAD SPACE, FIRE COLLAR - - G8 ADD STUD UNDER TRIPLE LVL - NORTH END - - 102 NAIL BOTTOM PLATE SHOWER - 104 FIRE COLLAR DEAD SPACE, ANCHOR BOLT SHOWER BEDROOM -
---	-------------	---

Corrective Action Required:

4	LOWER LEVEL	NORTH END -
---	-------------	-------------

G1 TIGHTEN ANCHOR BOLT -

Comments: