

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182387
Address: 2023 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Michael Harkins	Partial	Wednesday, May 06, 2020

Corrective Action Required:

1	Misc	LIGHT POLE BASE: 2 EAST SIDE, REAR LOT, WEST REAR LOT. OK TO POUR WHEN REBAR IS LIFTED AND BOTTOM IS CLEANED OUT. -- 3 DRIVE AT OVERHEAD DOORS / GROUND ROD REAR DOORS -
---	------	---

Comments: