

President

PRINCIPALS

Michael J. Falbe, P.E.

Steven R. Carroll, P.E. Richard C. Crabtree, P.E. Wayne E. Davis, P.E. Jeffrey L. Wright, P.E. Christopher W. Boos, P.E. Clark A. Basinger, P.E. Brandon M. Ford, P.E. Christopher A. Beverlin, P.E.

> Administrative Manager Paul M. Spena

4338 Belleview Ave.

816.531.4144

Kansas City, MO 64111 www.bdc-engrs.com

May 4, 2020

Mr. Warren Lewis Slaggie Architects 4600 Madison Kansas City, MO 64112

Re: **Summit Orchards**

Gloss Nails and The Flying Biscuit

460 NW Chipman Rd, Lee's Summit 64086

Dear Warren:

We have reviewed the roof framing for the rooftop mechanical equipment loading shown in the Tenant Improvement Package dated 04-24-20 and find that it has the required strength and stiffness to support this loading with the implementation of roof framing as required by General Note 5K and Section 2/S320 of the building shell construction documents.

Please call if you have any questions or if we may be of further service.

Sincerely,

BOB D. CAMPBELL & CO.

Structural Engineers

Clark A. Basinger, P.E., Principal

File / SLAGG1909 CC: