



### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20200716	Date:	May 07, 2020
Project Title:	CYCLEBAR	Applicant:	
Location:	910 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086		
Type of Work:	ABSOLUTE FIRE INC		
Occupancy Group:	A-4		13906 CENTURY LN
Description:	TENANT FINISH FOR EXERCISE		GRANDVIEW, MO 64030
	FACILITY WITH STATIONARY BIKES	Primary:	(816) 737-9991
Construction Type:	Type IIB (Unprotected)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.  
(Informational Purposes)  
Current annual inspection tag needed on riser.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**