



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20200717	Date:	May 07, 2020
Project Title:	PURE BARRE	Applicant:	
Location:			
910 NW BLUE PKWY, Unit:U, LEES SUMMIT, MO 64086		ABSOLUTE FIRE INC	
Type of Work:		13906 CENTURY LN	
Occupancy Group:	A-4	GRANDVIEW, MO 64030	
Description:	TENANT FINISH FOR EXERCISE	Primary: (816) 737-9991	
FACILITY WITH BALLET BARS			
Construction Type:	Type IIB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.
(Informational Purposes)
Current annual inspection tag needed on riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.