CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201099

Address: 1000 NE COLBERN RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Electrical Service Inspection - Khanh Nguyen Failed Thursday, May 07,

Commercial 2020

Corrective Action Required:

1 Misc -PROVIDE OVERCURRENT PROTECTION FOR THE FEEDER AT THE POINT WHERE

IT RECEIVES THE POWER

-CONNECT THE GEC TO THE UPPER RIGHT LUG WHERE THE SERVICE

GROUNDED CONDUCTOR IS CONNECTED TO. FYI: ONLY ONE CONDUCTOR PER

LUG UNLESS THELUG IS LISTED FOR TWO CONDUCTOR

-EXPOSE THE GROUNDING CO NNECTIONS TO RODS AT BOTH THE SERVICE

EQUIPMENT LOCATION AND AT THE TRAILER LOCATION

-UNBOND THE SUBPANEL ENCLOSURE FROM THE GROUNDED CONDUCTOR

Comments: