

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20182611  
Address: 901 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                      | Inspector: | Outcome: | Date:                     |
|----------------------------------|------------|----------|---------------------------|
| <b>Rated Assembly Inspection</b> | John Borns | Partial  | Monday, November 25, 2019 |

Partial Correction:

1 Misc

OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT STAIRWELL WALLS INSIDE FACE AND SPACES BETWEEN JOISTS AT BACKSIDE:

EAST STAIRWELL:

BASEMENT LEVEL: 1ST LAYER;  
1ST FLOOR: 1ST LAYER AT JOIST SPACES ONLY;  
2ND FLOOR:  
3RD FLOOR:  
4TH FLOOR:

WEST STAIRWELL: 1ST LAYER AT JOIST SPACES ONLY;

1ST FLOOR: 1ST LAYER AT JOIST SPACES ONLY;  
2ND FLOOR:  
3RD FLOOR:  
4TH FLOOR:

OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT ELEVATOR SHAFT WALLS AT:

BASEMENT LEVEL: 1ST LAYER AT JOIST SPACES ONLY;  
1ST FLOOR: 1ST LAYER AT JOIST SPACES ONLY;  
2ND FLOOR:  
3RD FLOOR:  
4TH FLOOR:

**Comments:**