

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20182652
Address: 2100 SW LADDERBACK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Street - Surface Course	John DiMauro	Passed	Thursday, May 07, 2020

Informational:

1 Misc

Superior Bowen was on site installing the surface asphalt lift for the roads. I verified that the correct mix type and temperature was used during the install. I verified that the correct equipment and install procedure was used during the install as well. The density testing lab was on site during the install and the preliminary results were in compliance. We will receive the testing results in the near future.

Comments: