CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193102 Address: 1824 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:	
All Rough Inspection - Residential		Michael Harkins	Failed	Thursday, May 07, 2020	
Corrective Action Required:					
1	Miscellaneous	cellaneous - PROVIDE HANGERS PER TRUSS LAYOUT SCHEDULE -			
	Correction	- BLOCK SHEATHING BREAK ABOVE SINGLE CAR GARAGE -			
	- OPEN PORCH LID TO EXPOSE HANGERS - - PROVIDE H 2.5S TRUSSES ABOVE FRONT DOOR/ STAIRWAY -				
	- PROVIDE 800 LB HOLD DOWNS EC#2 PER PLAN -				
- PROVIDE PFH PORTA - PROVIDE FLASHING - NAIL SHEATHING AT		- COMPLETE FURR DOWN	/NS GARAGE & GREAT ROOM -		
		- PROVIDE PFH PORTAL FF	ORTAL FRAME GARAGE DOOR PER PLAN -		
		- PROVIDE FLASHING HOR	RIZONTAL TRIM ABOVE GARAGE -		
		- NAIL SHEATHING AT FRC	SHEATHING AT FRONT PORCH WITH 8D NAILS PER PLAN NOT STAPLES		
		PENETRATIONS IN TYVEK NEED TAPED WITH TYVEK TAPE -			
		- PROVIDE PLUMBING NA	L GUARD LAUNDRY ROOM -		

Comments: