

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193102
Address: 1824 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Thursday, May 07, 2020

Corrective Action Required:

1	Miscellaneous Correction	<ul style="list-style-type: none">- PROVIDE HANGERS PER TRUSS LAYOUT SCHEDULE -- BLOCK SHEATHING BREAK ABOVE SINGLE CAR GARAGE -- OPEN PORCH LID TO EXPOSE HANGERS -- PROVIDE H 2.5S TRUSSES ABOVE FRONT DOOR/ STAIRWAY -- PROVIDE 800 LB HOLD DOWNS EC#2 PER PLAN -- COMPLETE FURR DOWNS GARAGE & GREAT ROOM -- PROVIDE PFH PORTAL FRAME GARAGE DOOR PER PLAN -- PROVIDE FLASHING HORIZONTAL TRIM ABOVE GARAGE -- NAIL SHEATHING AT FRONT PORCH WITH 8D NAILS PER PLAN NOT STAPLESPENETRATIONS IN TYVEK NEED TAPED WITH TYVEK TAPE -- PROVIDE PLUMBING NAIL GUARD LAUNDRY ROOM -
---	--------------------------	---

Comments: