

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20190941  
Address: 4520 SW NAUTILUS PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Friday, May 08, 2020

Corrective Action Required:

1 Misc

- \*\* All water is to be discharge 3' from foundation, sump pump discharge  
\*\* splash blocks needed - NO SPLASH BLOCKS IN PLACE

**Comments:**