

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20193662  
Address: 1113 NE GOSHEN CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Friday, May 08, 2020

Corrective Action Required:

1	Misc	<b>**CLEAN GRAVEL AND DIRT OFF THE STREET</b>
		-Complete roof ventilation above garage
		-Check beam size under kitchen lvl beam point load
		<b>**Install (4)2x4 support stud for the lvl beam; below in basement, install a steel column down to thicken slab</b>
		<b>**OK TO INSULATE</b>

**Comments:**