

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192500
Address: 1821 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Friday, May 08, 2020

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">• Submit as graded plot plan for review• Siding at garage door• Complete light fixtures at garage doors• Outlet covers at all receptacles• provide (2) 3" screws each exterior hinge and strike plate back door to deck• Hammer arrestors at laundry• Hammer arrestor at kitchen sink• Solid block above beam in basement• Terminate electrical receptacle exterior house rear• Complete grade and sod• Place splashblocks at all downspout and sump pump discharge locations for minimum distance from foundation 36"• Seal around all exterior light fixtures• Seal all exterior penetrations and along top of meter can and AC disconnect |
|---|------|--|

Comments: