

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193546
Address: 1516 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Michael Harkins	Failed	Friday, May 08, 2020

Corrective Action Required:

1	Misc	- PROVIDE (4) # 4 VERT BARS PER PLAN - (1) 24 X 36 (1) 24 x 48
---	------	---

Corrective Action Required:

2	Misc	REMOVE MUD AND WATER FROM EAST PIER (1) 36 X 53 (1) FULL OF MUD & WATER
---	------	--

Comments: