

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200272
Address: 4408 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Robb Popp	Failed	Friday, May 08, 2020

Corrective Action Required:
1 Misc - PROVIDE (4) # 4 VERTICAL BARS PER PLAN -
(2) 24 X 36
- STANDING WATER IN PIER -

Corrective Action Required:
2 Misc - INSPECTION DENIED LACKING EROSION CONTROL -

Comments: