

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193576
Address: 2927 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Monday, May 11, 2020

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Maintain silt fence, clean street -- Fire stopping at floor and ceiling penetrations, flue chase/heat chase 1st floor- (3) 2x10 floor joists flush between B piers in basement at stairs- Nail dbl truss per plans- Strap top plates at intersection of 3rd at NW corner |
|---|------|--|

Comments: