

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191159
Address: 120 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Robb Popp	Passed	Monday, May 11, 2020

Corrective Action Required:

1	Misc	4 light pole bases of east side wave pool. 5 light pole bases on south side 2 light pole bases on east side Bonding for shower Grounding of 5 South Pole bases
---	------	--

Comments: